

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7320-0065:144

Page 1 of 1

CATEGORY: Speakers

LISTEE: Faraday, Inc., 805 South Maumee St., Tecumseh, MI 49286
Contact: Steven A. Blohm (517) 423-2111

DESIGN: Models 2633, 2634, 2635 speakers and Models 2636, 2637 and 2638 speaker/strobes. Models 2636, 2637 or 2638 may be followed by suffix-A* (15cd), -B* (15cd), -C* (75cd), -N* (15cd), -W* (15cd), -D* (75cd) or -S* (110cd) to indicate strobe type and candela rating. Refer to strobe's listing for type and rating of strobe and listee's printed data sheet for detailed product description and operational considerations.

RATING: Electrical: 25 or 70.7 Vrms, 1/4W, 1/2W, 1W and 2W

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name or trademark "FOS", model number, electrical rating and UL label.

APPROVAL: Listed as speakers and speaker/strobes for use with separately listed electrically and functionally compatible fire alarm control units. For indoor use only. Units with strobe are also suitable for the hearing impaired applications.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition, the appliance must be used with a fire alarm control unit that can generate the temporal pattern signal. Refer to manufacturer's Installation Manual for details.

*Rev. 01-22-97



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **FEBRUARY 21, 2001**

*Listing Expires **June 30, 2002***

Authorized By: **BEN HO**, Supervising Deputy
Program Manager